



**Developments**

- ETC
- Highland Meadows Phase 2
- Lakeview Farms Phase 5
- Glade Bluffs Apartments
- 3430 Brodhead Road – Professional Building
- Center Grange Primary School
- Joe Hall Apartment Building

**SOLICITOR’S REPORT - Mr. Askar**

- 

**OPERATIONS SUPERVISOR REPORT- Mr. Martini**

- The DEP completed a yearly comprehensive evaluation inspection on 5/26/2022. All aspects of the operation were deemed compliant with only one noted violation of reported sanitary sewer overflows on the Lower Moon Run Trunk Line.
- We have working on updating all the Lab SOP’s for review by DEP in anticipation of our inspection later this year.
- Logstown Lift Station has a blown gasket in the piping located in the wet well. Lone Pine construction will be on-site this Wednesday to repair. By-pass pumping of sewage to Hopewell will be necessary. I will research installing a vault to eliminate the by-passing event to Hopewell in the near future.

**CLERK- Ms. Martini**

- 

**OLD BUSINESS**

- Letter to Beaver Valley Mall to be sent informing of excessive infiltration / inflow within their sanitary sewer system. – On Hold.
- Right – of – way agreement with Mr. James Quinn on his property next to I-376.

**NEW BUSINESS**

- 

**MOTION TO ADJOURN THE MEETING****MOTION:****SECOND:****ALL IN FAVOR****ANY OPPOSED- NONE****MOTION CARRIED**

There being no further business to come before this meeting, the same was adjourned at approximately \_\_\_\_\_ p.m.

Respectfully submitted,  
Brooke Martini  
Accounts Specialist